

9/2/2015

Gmail - 916 N. Western gutters



Moe Solifos <solifos@gmail.com>

916 N. Western gutters

Cage, Ed <ecage@parkridge.us>
To: Joe Solomon <solifos@gmail.com>

Wed, Oct 29, 2014 at 2:31 PM

Hi Joe,

I talked to Lonnie about the drawing you submitted for the deck/treehouse and we have a setback and height issue. The setback needs to be 5-feet and the maximum height is 15-feet. The variance option is going to be tough because your neighbor will come to the meetings and it will not go smoothly.

Do you have any thoughts/ideas on bringing it into compliance?

Thanks,

Ed.

From: Joe Solomon [mailto:solifos@gmail.com]
Sent: Friday, October 24, 2014 12:26 AM
To: Cage, Ed
Subject: Re: 916 N. Western gutters

Sounds good. We will submit the permit tomorrow (Friday). And here's the drawing.

Thanks,

Joe

[Quoted text hidden]

